

Alachua County Public Works Department

Ramon D. Gavarrete, P. E. Public Works Director

Public Works Ramon D. Gavarrete, P.E. Public Works Director

rgavarrete@alachuacounty.us

Tel: (352) 374-5245 Fax: (352) 337-6243

Fleet Management Gerald Bailey

Fleet Manager gbailey@alachuacounty.us

Tel: (386) 462-1975 Fax: (386) 418-0331

Solid Waste and Resource Recovery Department Patrick Irby

Interim Solid Waste and Resource Recovery Director pirby@alachuacounty.us

Tel: (352) 374-5213 Fax: (352) 337-6244

Administration Kenneth Fair, CPA,CGFO

Sr. Administrative Support Manager kfair@alachuacounty.us

Tel: (352) 374-5245 Fax: (352) 337-6244 **September 16, 2019**

MEMORANDUM

TO: Charles Chestnut, IV, Chair

Alachua County Board of County Commissioners

FROM: Ramon D. Gavarrete, P.E., Public Works Director

Alachua County Public Works

SUBJECT: Special Pay Request – Brooks Building Solutions

There was a water main break at the Alachua County Jail due to the age of the infrastructure. The break required potable water to be shut off at the jail while the water main break was being repaired. A chiller plant is operated at the jail for HVAC. The chiller plant is fed by the potable water system and there is a groundwater well for back-up water supply in the event potable water is not available. During the repair, the chiller plant failed due to not having enough water supply. It was discovered the water line from the well to the chiller plant was undersized (0.5 inch) and could not supply the volume of water required to run the plant; the well supply line was upsized (1.5 inch) to adequately supply the plant. Brooks Building Solutions was authorized to upsize the line without a PO in place in order to get HVAC running at the jail while the water main was being repaired. The Department requests approval of Brooks Building Solutions invoice 29510 in the amount of \$5,662.38 for this work.

RDG:BMS