



Alachua County Budget and Fiscal Services Procurement

Larry M. Sapp, CPPB
Procurement Manager

Darryl R. Kight, CPPB
Procurement Supervisor

February 10, 2021

RE: Addendum #2
BID 21-965 Camp Cuscowilla Pool Renovations - Project # 8204102

Dear Sir/Madam:

Please be aware of the following clarifications regarding the above referenced Bid:

QUESTION AND ANSWERS:

Q #1: Is abrasive blasting an approved method of surface preparation of the swimming pool surface?

A #1: Yes, as long as it removes existing masonry down to the concrete and the blasting media can be contained in the pool.

NOTE: You should acknowledge receipt of this addendum on your Bid Form.

End of Addendum # 2

Sincerely,

Theodore White

Theodore White
Procurement Agent II

TW/bf