



Legislation Details (With Text)

File #: 22-0536 **Version:** 1 **Name:**
Type: Notation for Record **Status:** Agenda Ready
File created: 6/15/2022 **In control:** Board of County Commissioners
On agenda: 9/13/2022 **Final action:**
Title: "FOR INFORMATION ONLY", for inclusion into the Board's minutes, Signed Emergency Certification Form and a Purchase Order to Eola Power, LLC., in the amount of \$118,534.15, for the replacement of the Uninterrupted Power Supply Unit (UPS) equipment at the Alachua County Combined Communications Center Building for Public Works, Critical Facilities.

Sponsors:

Indexes:

Code sections:

Attachments: 1. Emergency Certification Form POR 22-1924_EOLA_CCC_UPS Replacement - signed by Chair.pdf, 2. Quote Eola #11019 08.15.2022, Riello MGF.pdf, 3. zDept EM, New UPS, CCC, Status.pdf

Date	Ver.	Action By	Action	Result
------	------	-----------	--------	--------

Agenda Item Name:

"FOR INFORMATION ONLY", for inclusion into the Board's minutes, Signed Emergency Certification Form and a Purchase Order to Eola Power, LLC., in the amount of \$118,534.15, for the replacement of the Uninterrupted Power Supply Unit (UPS) equipment at the Alachua County Combined Communications Center Building for Public Works, Critical Facilities.

Presenter:

Ramon D, Gavarrete, 352.548.1214/Larry Sapp, 352.374.5202

Description:

Eola Power, LLC., Emergency Purchase Order

Recommended Action:

Accept this report of the emergency purchase and include the signed Emergency Certification Form and a copy of the emergency purchase order in the Board's minutes.

Prior Board Motions:

September 28, 2021 - Final Budget Approval for FY21-22 Annual Budget with Capital Preservation Project for replacement of UPS at Combined Communications Center

Fiscal Consideration:

Sufficient budget exists in account 001.19.1919.529.46.00 in Project # 8211902-FY22-UPS - Combined Communication Center Building, FY22 Allocation, Liebert 80KV Single Model UPS

Strategic Guide:

Infrastructure

Background:

The existing Uninterrupted Power Supply Unit (Liebert AP356) at the Combined Communications Center is in critical condition risking the entire load of the Center. The components are in danger of causing an arc flash/fire event. In addition, we are in hurricane season, therefore, it is imperative we replace the UPS at the CCC to ensure safe and continued operations.

This purchase is exempt from the County's competitive bidding requirements pursuant to Section 22.3-302(16) of the Alachua County Procurement Code, Emergency Procurements in accordance with the Procurement Procedures Manual. However, since the dollar amount of the purchase exceeds the purchasing authority of the Procurement Manager, this Purchase Order is being submitted for Board consideration and approval.